

A Matrix for Distributed Energy Resource Technologies

A complex series of developments in distributed energy is taking place. The matrix which follows gives an overall view of the primary types of distributed energy and storage systems as they relate to development status, operational characteristics, maintenance, siting, environment, performance, and power quality.

This information has been provided by the CADER (California Alliance for Distributed Energy Resources) Technology Characterization Committee. CADER and the subcommittee make no claim or warranty regarding the accuracy or validity of the data contained in this matrix.

As the new millennium approaches, the electric industry is preparing for a fundamental shift in the way power is produced. The next century will feature smaller generating units in a range of sizes to accommodate homes, restaurants, shopping malls, industrial plants, as well as strategic use on distribution and transmission systems.

This matrix reviews the range of technologies already available, including turbines, reciprocating engines, renewables (solar, wind and biomass) and storage systems. Advanced and emerging technologies—such as fuel cells and microturbines—are expected to join the roster in the next 2-5 years.

These generating technologies, combined with storage systems, efficiency technology and load management, are referred to as “Distributed Energy Resources” (DER). Together these new strategies promise greater energy efficiency, lower prices, higher quality of service, and a cleaner environment.

Electric utilities and consumers will have greater choices than ever before. Government initiatives on both the federal and state level are gearing up to change the rules to allow “Plug and Play” generation sets. These issues include: interconnection rules with electric utilities, rates and tariffs for backup and standby services, air quality regulations and permitting and building codes.

CADER Technology Characterization Subcommittee

DEVELOPMENT STATUS				OPERATION				
Current Status (Dev, Demo, Comm)	Year	Rated Full Load Not Capacity (kWe)	Rated Minimum Load (%FL)	Usable Thermal Output (Btu/kWh)	Usable Thermal Temperature (F)	Dispatchable?	Practical Load Duty (Bass, Intern., Peak)	Fuel(s) Specifications
GENERATION								
Reciprocating UCs								
Diesel	Comm	50-5,000	50	3,400	185-900	No	B,I,P	Diesel >2.0 psig
Otto (Spark Ignition)	Comm	50-6,000	50	1,000-5,000	316-500	No	B,I,P	Biogas Natural Gas 1.0-45 psig Propane
Gas Turbines								
Micro-Turbines	Dev/Demo	25-250	0-50	4,000-15,480	400-635	No	B,I,P	Nat. Gas; Diesel; Propane; Multi fuel 3-100 psig
Small Gas Turbines	Dev/Comm.	500-10,000	5-50	3,400-12,000	500-1,100	No	B,I,P	Nat. Gas Distillate; Biogas 140-500 psig

CADER Technology Characterization Subcommittee (Continued)

DEVELOPMENT STATUS		OPERATION									
Current Status (Dev, Demo, Comm) Compatible	Year Commercial Fuel	Rated Full Load Not Capacity (kWe)	Rated Minimum Load (%FL)	Usable Thermal Output (Btu/kWh)	Usable Thermal Temperature (F)	Operator?	Dispatchable?	Practical Load Duty (Bass Interim, Peak)	Fuel(s)	Specifications	
Fuel Cells											
Molten Carbonate	2000-2003	250-2,850	25-30	1,400-1,800	170-710	No	Yes	B,I	Nat. Gas	15-45 psig	
Phosphoric Acid	1998	200	0	3,500-3,750	140-250	No	Yes	B,I	Nat Gas Propane	15-5 psi	
Proton Exchange Membrane	1998-2000	3-250	0-33	2,000-3,250	135-165	No	Yes	B,I,P	Nat. Gas Propane, Butane, Diesel	gas pipeline press	
Hybrid Solid Oxide	2001-2003	225-2,240	25	540-1,100	350-420	No	Yes	B,I	Nat. Gas	None Reported	
Solar Electric											
Photovoltaics	Dev/Demo/Comm	10-10,000	0	0	0	No	No	P	Solar		
Dish Stirling	1999	5-25	0-10	6,800	150	No	Yes (when fossilised fueled)	B,I,P	Solar. Fossil Fuels	>300 W/m ²	
Wind Turbines											
<50 kW	Comm	0.85-50	1	0	0	No	No	P (w/storage)	Wind	>8 MPH Wind	
>50 kW	Comm	50-1,000	1	0	0	No	No	I	Wind	>10 MPH Wind	

CADER Technology Characterization Subcommittee (Continued)

DEVELOPMENT STATUS				OPERATION					
Current Status (Dev, Demo, Comm)	Year	Rated Full Load Not Capacity (kWe)	Rated Minimum Load (%FL)	Usable Thermal Output (Btu/kWh)	Usable Thermal Temperature (F)	Dispatchable?	Practical Load Duty (Bass, Interim, Peak)	Fuel(s)	Specifications
STORAGE									
Batteries	Dev/Demo/Comm	1997-2000	100-20,000			Yes	B,LP	Electricity	N/A
Flywheels	Dev/Demo/Comm	1997-2000	10-3,000	0-10	0	Yes	P	Electricity	N/A
MAINTENANCE									
Cold Start-Up Time (minutes)	Annual Maintenance Hours (hrs/yr)	Time Before Intervention (opr hrs)	Time Between Overhauls (opr hrs)	Power Plant Size	Infrastructure Needs				
SITING & ENVIRONMENTAL									
GENERATION									
Reciprocating YCs									
Diesel	0.167	20-250	1,500-2,000	25,000-30,000	22	Engine Coolant	No	Yes	Yes
Otto (Spark Ignition)	0.017-0.167	20-250	280-1,000	24,000-60,000	22-31	3-6	22-65	Engine Coolant	No
Gas Turbines									
Micro-Turbines	0.5-1.0	1-20	750-10,000	5,000-40,000	0.15-1.5	0.6-4.0	2.6-37	None Reported	None Reported
Small Gas Turbines	1.0-100	50-700	4,000-8,000	30,000-50,000	02-61	30-1.06	7-26	None Reported	None Reported

CADER Technology Characterization Subcommittee (*Continued*)

MAINTENANCE										SITING & ENVIRONMENTAL										
	Cold Start-Up Time (minutes)	Annual Maintenance Hours (hrs/yr)	Time Before Intervention (opr hrs)	Time Between Overhauls (opr hrs)	Power Plant Size			Infrastructure Needs												
					Footprint (sqft/kW)	Volume (cuft/kW)	Weight (lb/kW)	Water Service	Waste Water Service	Fuel Delivery	Maint. Access	Telcom- munciations,								
Fuel cells																				
Molten Carbonate	1,200-2,400	120	720	40,000	1-4	8-40	120-240	Yes or No	Yes or No	Yes	Yes	Yes	Optional							
Phosphoric Acid	180	50-55	2,200-8,760	40,000	4	40	200	None Reported	None Reported	Yes	Yes	Yes	Yes							
Proton Exchange Membrane	60	4	8,700	8,700-40,000	0.6-3	4.7-9	100-300	Possible	None Reported	Yes	Yes	Yes	Optional							
Hybrid Solid Oxide	2 (see note)	40	8,000	40,000	1.1-1.2	18-20		None Reported	None Reported	Yes	Yes	Yes	Optional							
Solar Electric																				
Photovoltaics	0					538		None	None	No	Yes	Optional								
Dish Stirling	3-5	6-10	8,000	30,000	160-269	600		None	None	No	Yes	No								
Wind Turbines																				
<50 kW	08-16	0.25	30,000	200,000	15-9.0	9.24	330-720	None	None	No	Yes	No								
>50 kW	0.16-0.5	40	4,000	130,000	0.24-110	250		None	None	No	Yes	Optional								
STORAGE																				
Batteries																				
	0-004	120-150	8,700		1-7	124-186		None	None	Yes (Electricity)	Yes	Optional								

CADER Technology Characterization Subcommittee (Continued)

DEVELOPMENT STATUS		OPERATION									
Current Status (Dev, Demo, Comm) Compatible	Year Commercial Fuel	Rated Full Load Not Capacity (kWe)	Rated Minimum Load (%FL)	Usable Thermal Output (Btu/kWh)	Usable Thermal Temperature (F)	Operator?	Dispatchable? (Interim, Peak)	Practical Load Duty (Interim, Peak)	Fuel(s)	Specifications	
Flywheels	0-40	8,700-18,000	10,000-175,000	.013-.830	0.5-6.0	1.3-17	None	None	Yes (Electricity)	Optional	
SITING & ENVIRONMENTAL											
Air Emission Controls	CO	CO	NOx	SOx	UHC	PM10	Noise (dB @ 7 ft)	Water Consumption (Gal./kWh)	Waste Water Production (Gal./kWh)	Hazardous Materials	Other Hazards
Reciprocating I/Cs	Diesel	None Reported	.022-.025	60-85 dB @ 25 ft	Nearly Zero Reported	Zero Reported	None Reported	None Reported	None Reported	None Reported	None Reported
Otto (Spark Ignition)	None Reported, SCR	0.473-0.525	0.004-0.037	0.0	0.0009	0.0002	100 @ 3.3 R	Nearly Zero Reported	Zero Reported	None Reported	None Reported
Gas Turbines	Micro-Turbines	None Reported, Catalytic	3-50 ppm	Negligible 3-9 ppm	Negl.	<60 dB @ 33 ft	Zero Reported	Zero Reported	None Reported	None Reported	Batteries
Small Gas Turbines	None Reported, Water/Steam injection, SCR, OLN Comb.	<15-50 ppm	.007-.09	Negl.	<15-25 ppm	60-85 @ 23 ft	85 dB @ 3 ft	Zero Reported	Zero Reported	None Reported	None Reported

CADER Technology Characterization Subcommittee (Continued)

SITING & ENVIRONMENTAL

	Air Emission Controls		Air Emissions (lb/kWh, unless indicated otherwise)				Noise (dB @ 7 ft)	Water Consumption (Gal./kWh)	Waste Water Production (Gal./kWh)	Hazardous Materials	Other Hazards
	CO	CO	NOx	SOx	UHC	PM10					
Fuel Cells											
Molten Carbonate	None Reported	0.785-0.9	0.00001	<0.000002	<0.000003	Negl.	60 dB @ 30 ft dB @ 100 ft	0-0.125	0-0.044	None Reported	None Reported
Phosphoric Acid	None Reported	1.13	0.000023	0	0.000016	0.0000004	0	62 dB @ 30 ft	Zero Reported	None Reported	None Reported
Proton Exchange Membrane	None Reported	1.1-1.5	Negl.	Negl.	0	0	50 dB @10 ft 65 dB @ .10 ft	0-0.2	Zero Reported	Batteries	None Reported
Hybrid Solid Oxide	None Reported	0.7	0.0	0.00005- 0.00006	0	0	60 dB @ 30 ft	Zero Reported	Zero Reported	Spent Desulfurizer Reagent	None Reported
Solar Electric											
Photovoltaics	None	0	0	0	0	0	0	0	0	None	None Reported
Dish Stirling	Low NOx Burner	.02	.02	.02	.02	.02	Negligible	0	0	Hydrogen	None Reported
Wind Turbines											
<50 kW	N/A	N/A	N/A	N/A	N/A	N/A	58-64 @ 100 ft	0	0	Batteries	None Reported
<50 kW	N/A	N/A	N/A	N/A	N/A	N/A	45 dB @ 820 ft	0	0	Hydraulic Fluid	Aviary Hazard

CADER Technology Characterization Subcommittee (Continued)

	ECONOMICS										Variable Non-Fuel (\$/kWh)	Power Plant
	Net Electric Heat Rate (HHV Btu/kWh)	Full Load (100% FL)	Reduced Load (75% FL)	Mid-Load (50%FL)	Expected Availability	Typical Forced Outage Rate	Load Ramp Rate (kW/min)	Capital Cost (\$/kW)	Installation	Fixed O&M		
Micro-Turbines	10,300-16,484	11,300-17,000	12,200-25,043	92-98+	1-5	25-250	250-1,250	35-150	0.002-0.10	5-20+		
Small Gas Turbines	8,400-16,000	9,000-11,000	9,850-12,200	90-98	1-3		300-870	50-120	0.02-0.08	20-50		
Fuel Cells												
Molten Carbonate	6,545-7,580	6,270-8,040	6,100-9,090	>95%	<5%	7-285	815-1,900	100-435	70	0.03	30-35	
Phosphoric Acid	9,450	9,450	9,450	97.7	1.2	80kW instantaneous step load change increase while operating, grid independent	3000	450-750	0.08-0.10	20		
Proton Exchange Membrane	9,492-9,763	9,235-9,492	8,543-9,492	>95	<1	0.5	4,000	1,000	0.010-0.045	15-25		
Hybrid Solid Oxide	5,380-6,120	6,110-6,640	6,240-6,670	94	4		1,150-1,300	180-230	25-50	.02-0.03	30	
Solar Electric												
Photovoltaics	22,780 solar to electric						5,000-10,000		0.01-0.04			
Dish Stirling	8,400-16,600	11,000-18,500	16,700-21,500	95			3,800-4,000		.05-0.25			
Wind Turbines												
<50 kW	N/A	N/A	N/A	95-99	0-1	N/A	2,600-4,600	1,000-4,000		30		

CADER Technology Characterization Subcommittee (Continued)

PERFORMANCE		ECONOMICS										Variable Non-Fuel (\$/kWh)	Power Plant
		Net Electric Heat Rate (HHV Btu/kWh)	Full Load (100% FL) (75% FL)	Reduced Load (50%FL)	Expected Availability	Typical Forced Outage Rate	Load Ramp Rate (kW/min)	Capital Cost (\$/kW)	Installation	Fixed O&M			
>50kW		N/A	N/A	N/A	N/A	N/A	850-1,500	60-175	4.2-70	003-021	20-25		
STORAGE													
Batteries		N/A	N/A	N/A	100%	0-0.55%	Nearly Instantaneous to Full Load	200-416	10-42	0076	30		
Flywheels		N/A	N/A	N/A	>95%	0	Nearly Instantaneous to Full Load	30-480	4-5		10-30		
POWER QUALITY													
Construction Lead Time (months)		3-12	8-9	5	0.8-1.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Voltage THD (%)		5	<5%	<5%	0.8-1.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Current THD(%)		5	<5%	<5%	0.8-1.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Full Load Power Factor		0.8-1.0	0.8-1.0	0.8-1.0	0.8-1.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Stored Energy Capacity (kWh)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Discharge/Charge Efficiency (%)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Stand-By Losses (1% cap/hr)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Time-to-Charge (hrs)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
ENERGY STORAGE													
OTHER ATTRIBUTES													
GENERATION													
Reciprocating VCs													
Diesel		3-12	8-9	5	0.8-1.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Otto (Spark/Ignition)		3-12	8-9	5	0.8-1.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Gas Turbines													
Micro-Turbines		0-1	<5%	<5%	0.8-1.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Emissions data at 15% O2
Small Gas Turbines		3-16				N/A	N/A	N/A	N/A	N/A	N/A	N/A	Includes Advanced Simple Cycle GT Data Emissions data at 15% O2

CADER Technology Characterization Subcommittee (Continued)

		POWER QUALITY				ENERGY STORAGE			OTHER ATTRIBUTES	
		Construction Lead Time (months)	Voltage THD (%)	Current THD(%)	Full Load Power Factor	Stored Energy Capacity (kWh)	Discharge/Charge Efficiency (%)	Stand-By Losses (1% cap/yr)	Time-to-Charge (hrs)	
Fuel Cells										
	Molten Carbonate	12-24	<3%	<3%	0.85-1.0 lead or lag	N/A	N/A	N/A	N/A	N/A
	Phosphoric Acid	7	<3% balanced linear load		.65 lead or lag	N/A	N/A	N/A	N/A	N/A
	Proton Exchange Membrane	1	<5%	<5%	.8 lead or lag	4	40		4	
	Hybrid Solid Oxide	3-6	Per IEEE Specs.	Per IEEE Specs.	1.0	N/A	N/A	N/A	N/A	N/A
Solar Electric										
	Photovoltaics Disk Stirling	1	0.5	05		N/A	N/A	N/A	N/A	N/A
Wind Turbines										
	<50 kW	2	0.03	0.05	0.98					Integral storage under development for DC applications
	<50 kW	8-12			leading or lagging controller	N/A	N/A	N/A	N/A	N/A

O&M Site Dependent. Early production units are projected to be available in 2001 at the higher capital cost. Installation does not include the cost of land transformer, switch gear and project development. Fixed O&M includes cost of major overhauls every five years.

Aggregated data includes small power plant integrated with battery storage. Next generation designs include integration with Brayton cycle turbine. Cold start-up time is for gas turbine. SOFC requires hours for start-up.

Hybrid design can also use fossil fuels, such as natural gas.

Integral storage under development for DC applications

ABOUT CADER

The California Alliance for Distributed Energy Resources (CADER) is dedicated to successfully facilitating a smooth deployment of economic, efficient and environmentally friendly distributed energy resources into the competitive energy market. Members in CADER represent all aspects of the energy industry and are focused on providing objective and much needed information on DER to the government, industry and consumers alike. While CADER's initial focus was on California, it is now broadening its membership to accommodate national coverage and dedicates its efforts to facilitate the DER industry.

For further information contact Jairam Gopal, Chair, CADER, 916-654-4880, fax 916-654-4753; jgopal@energy.state.ca.us